



**ADDENDUM 001
REQUEST FOR QUOTE
Replace Shingle Roof
Request for Quote (Q10-11338-TB)**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including it** with the original quote. The due date for receipt of proposals remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

1.0 Shingled Roof - Contractor to remove & properly dispose of all items down to the wood surface including but not limited to shingles, feltpaper, drip edge, nails, and damaged vent boots. There are at least 2 layers of shingles on this roof. Contractor will then install tarpaper, drip edge, new roof boots, flashing and shingles at the Qulin Maintenance Facility. All new drip edge, 30 lb. felt paper and ridge vent. This building is 90' x 38'. Bidder is responsible for visiting the site to get true measurements. The old chimney will NOT be removed. The replacement roof should be a 30-Year Architectural Shingle in a Rustic Cedar color.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name Tammy Baker Title Procurement Agent
Contractor/Offer or Signature (Signature of person authorized to sign)	Department of Transportation <i>Tammy Baker</i> (Authorizing Signature)
Date Signed:	Date Signed: December 29, 2010